



Analysis Report

District Level Water Analysis Laboratory U.P. Jal Nigam
(RURAL)

Near M.B.Inter Collage, Gandhi Nagar, Bareilly (U.P.)



U/LR No :- TC-14194-2600002308F

Customer Details

Office Name and Address : HANDA PUBLIC SCHOOL, MODERN VILLAGE, DOHNA, NAINITAL
ROAD, BAREILLY.

Ref Letter No & Date : NIL DATE - 22-04-2026 Report No - LAB/BL/2026-27/2308

Basic details of sample

District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	22-04-2026
Village/AREA	MODERN VILLAGE	Block	-		
Habitation	MODERN VILLAGE	Location	HANDA PUBLIC SCHOOL	Analysis Completion Date	22-04-2026
Water Source	Submersible	Sample Code	PS- 2308		
Quantity of Sample	1 ltr	Date of Sample Collection	18-04-2026	Report Issue Date	22-04-2026
Receiving Date	22-04-2026	Sample Collector (Lab)	VIPIN KUMAR	Sample Depositor	Kuldeep
Water Source	SOURCE IS NOT VERIFIED BY LABORATORY.				

Sampling Method - ISI 17614 (Part-1:2021)

Environmental Condition

Temperature 27°C Humidity 53%

Technical Data of Analysis

S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Value as per IS 10500:2012		Ref.Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(CU)	0	5	15	IS 3025 (Part 4) 2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) 2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) 2023
4	Turbidity	(NTU)	0.21	1.00	5.00	IS 3025 (Part 10) 2023
5	TDS	(mg/L)	149	500	2000	IS 3025 (Part 16) 2023
6	PH	-	7.46	6.5-8.5	6.5-8.5	IS 3025 (Part 11) 2022
7	Iron	(mg/L)	-	1.00	1.00	IS 3025 (Part-53) 2024
8	Sulphate	(mg/L)	-	200	400	IS 3025 (Part 24) 2022
9	Alkalinity	(mg/L)	138	200	600	IS 3025 (Part 23) 2023
10	Hardness	(mg/L)	130	200	600	IS 3025 (Part 21) 2019
11	Chloride	(mg/L)	11	250	1000	IS 3025 (Part 32) 2019
12	Calcium	(mg/L)	26.4	75	200	IS 3025 (Part-40) 2024
13	Magnesium	(mg/L)	15.55	30	100	APHA 23 Edition 3500Mg Method B
14	Fluoride	(mg/L)	0.044	1	1.5	IS 3025 (Part-60) 2023

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Page no -1/1

Email - anamika95@gmail.com
U.P.JALNIGAM (RURAL) Contact No- 7318253236

Authorized signatory

अनिल कुमार
/ गुणवत्ता प्रबन्धक
जल विश्लेषण प्रयोगशाला
उ० प्र० जल निगम बरेली (ग्रामीण)

END OF THE REPORT

Annexure C

Appendix-XIII

CERTIFICATE SAFE DRINKING WATER AND SANITARY CONDITION

Dated: 22/04/2026

No: - TC-14194-2600002308F

It is certified that an inspection team headed by **Naveen Suri (SAMPLING ASSISTANT)** (Name of Officers with designation) from **UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY** inspected **HANDA PUBLIC SCHOOL, MODERN VILLAGE, DOHNA, NAINITAL ROAD, BAREILLY, UTTAR PRADESH** on 22/04/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **LAB/BLY/2026-27/2308** dated 22.04.2026 Of **UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab)** certified that **HANDA PUBLIC SCHOOL, MODERN VILLAGE, DOHNA, NAINITAL ROAD, BAREILLY, UTTAR PRADESH** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid from 22-04-2026 to 21-04-2027.

Signature with Seal:

Name : RUMAN SAGHIR

Designation: (AE)


Assistant Engineer
Division Office
U.P. Jal Nigam (Rural) Bareilly

Name & Address of the Office / Department- UP JAL NIGAM BAREILLY (RURAL).

To
MANAGER

**HANDA PUBLIC SCHOOL, MODERN VILLAGE,
DOHNA, NAINITAL ROAD, BAREILLY,
UTTAR PRADESH.**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies